

DOCUMENT 00 91 13
ADDENDUM NO. 2

August 13, 2020

RE: Kaytena Township - Hwy 160 Lighting
1902-280

FROM: Kayenta Township
100 N. Highway 163
Box 1490
Kayenta, AZ 86033

TO: Prospective Bidders

This addendum forms a part of the Contract Documents and modifies the original Procurement Documents, dated July 2020, and Addendum No. 1, dated July 2020, as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of 1 page and 1 attachment.

CHANGES TO PROCUREMENT REQUIREMENTS:

1. Document 00 11 13 – Advertisement for Bids
 - a. Change bid opening date to August 17th, 2020.
 - b. Provide zoom meeting link for bid opening <https://zoom.us/j/99406605703>.

RESPONSES TO BIDDER QUESTIONS:

1. Do we bond the whole project with the additive or do we bond them separately with two different checks? [Single bond for the entire project including additive bid items.](#)
2. Do you want the bid price with the bid documents all together in one envelope? [Submit all bid documents and the bid price in the same envelope.](#)
3. Is there boring under the main road? [No, borings are on minor roads and paved accesses. There are no anticipated borings crossing US-160 or US-163](#)
4. Have permits been pulled for NTUA to provide power? [Kayenta Township has started the permitting with NTUA. Contractor coordination with NTUA](#)

DOCUMENT 00 91 13
ADDENDUM NO. 2

will be required. Contractor will be required to pull ADOT encroachment permit.

5. Is there compaction testing for base and trench? Meet ADOT requirements for compaction in shoulders. Quality Control testing for compaction by Township is not anticipated.
6. Will ADOT have an inspector on-site throughout the project or intermittently? It is anticipated that ADOT will inspect intermittently
7. Will township also provide anchor bolts for poles? Yes
8. Is concrete testing for every truck or pour? We will test each truck
9. There are companies that pre-manufacture light pole bases. Is that something that can be permitted with this project? No, ADOT does not allow alternate foundation types in their right-of-way
10. There is a foundation that is drilled. Can that be used for light pole bases? No, ADOT does not allow alternate foundation types in their right-of-way

Signed:


Heston Zornie, Project Manager

END OF ADDENDUM



**ADVERTISEMENT
INVITATION FOR BID**
CONSTRUCTION SERVICE FOR INSTALLATION OF
U.S. HIGHWAY 160 STREET LIGHT POLES IN KAYENTA, ARIZONA

The KAYENTA TOWNSHIP invites all Licensed General Contractors to bid on the Construction Services for installation of (50) ADOT Street Light Poles along the U.S. Highway 160 within the Township boundaries in Kayenta, Arizona. The KAYENTA TOWNSHIP will receive Sealed Bids until **10:00 am (MDST)** on **August 17, 2020** at the Kayenta Township or mail to: Kayenta Township, Attn: Heston Zonnie, P.O. Box 1490, Kayenta, AZ 86033. Bids will be opened and publicly read aloud immediately after the specified closing time. Bid opening can be viewed via a virtual Zoom meeting at <https://zoom.us/j/99406605703> . A **Pre-bid Conference** will be held on **August 3, 2020** at **10 am (MDST)** via a virtual Zoom Meeting at <https://zoom.us/j/93737711543>. This invitation is open to all contractors; however preference will be given to Navajo Owned Businesses. Award will be made in accordance with the Navajo Nation Business Opportunity Act, Title 5, Chapter 2, Section 205 et. seq. where applicable. The selected General Contractor shall comply with all applicable laws, rules and regulations of the Navajo Nation including without limitation, the Navajo Preference in Employment Act (NPEA). All questions regarding this IFB shall be directed to: Heston Zonnie, Project Manager, email: hzonnie@kayentatownship-nsn.gov. Licensed General Contractors may request for electronic copies of the bid documents from the Kayenta Township by phone (928) 697-8451 or email: hzonnie@kayentatownship-nsn.gov.